

Annexure C

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. 256

Dated: 17-03-2025

It is certified that an inspection team headed by ...Sachin Kumar Engineer.....

(Name of Officers with designation) from Water Supply & Sanitation Dept: PHED

inspected the GARDEN VALLEY INTERNATIONAL SCHOOL, KOTLA BAJWARA

(Name & Address of the school) on 24/03/25.....(date of inspection) and on the basis of

Water Test Report (Attached) bearing no. DWT.LF.45/2425/00449..... dated 10/03/2025..

of DISTRICT WATER TESTING LAB, FATEHGARH SAHIB (PHED Lab) certified that

the GARDEN VALLEY INTERNATIONAL SCHOOL.....(Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.

This certificate is valid till 31-03-2026.....

Signature with Seal:

Name

Designation

Name & Address of the Office / Department :

WATER SUPPLY & SANITATION DEPARTMENT
SUB DIVISION, KHERA AT FATEHGARH SAHIB

To

(Name & Address of the Institution)

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies

M. Ankit
Principal
Garden Valley International School
Kotla Bajwara, Sirhind *

For Shaheed Bhagat Singh Educational
Trust & Management Society

[Signature]
Authorised Signatory

DISTRICT WATER TESTING LABORATORY, FATEHGARH SAHIB

Water Supply & Sanitation Division, Opposite DC Residence, Fatehgarh Sahib

dwtlfgs@gmail.com



TC-12711

TEST REPORT

Name & Address of Customer : Principal Garden Valley International School Kotla Bajwara, Sirhind		Customer Reference No.	No : Dated : 24/02/2025
		Sample Submitted by	
		Date of Sample Receipt	24/02/2025
		Analysis Starting Date	24/02/2025
		Analysis completion Date	25/02/2025
Discipline : Chemical Testing		Group: Water	
ULR No.:	TC127112500000114F	Sample Type :	Water
Test Report No.:	DWTLFGS/2425/00449	Date of Issue :	10/03/2025
Registration no.:	DWTLFGS/REG2425/01546	Condition of Sample :	Unsealed
Collection Point:	Treatment Plant (RO/CWPP/ARP/HH Purifier)	Quantity/Type of Bottle:	500 ml / Amber Colored Glass Bottle
Scheme/Source:	Not Mentioned(Not Mentioned)	Location/Depth :	Garden Valley International School Kotla Bajwara, Sirhind / NA
Village :	Kotla Bajwara	Habitation :	Kotla Bajwara
Block:	Khera	District :	Fatehgarh Sahib
Latitude :	Not Mentioned	Longitude:	Not Mentioned

Sr. No	Parameter	Result	As per IS-10500:2012 (2nd Rev.)		Unit	Reference Method :
			Acceptable Limit	Permissible Limit		
1	pH	7.49	6.5-8.5	No Relaxation	--	IS 3025 (Part 11-2022) Electrometric Method
2	Colour	1	5	15	CU	IS 3025(Part 4-2021) Visual Comparison Method
3	Odour	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 5 – 2018) (Second Revision)
4	Taste	Agreeable	Agreeable	Agreeable	--	IS 3025 (Part 8 – 2023)
5	TDS	150	500	2000	mg/l	IS 3025 (Part 16-2023) Gravimetric Method
6	Turbidity	BDL	1	5	NTU	IS 3025 (Part 10-2023) Nephelometric Method
7	Alkalinity(CaCO ₃)	72	200	600	mg/l	IS 3025 (Part 23-2023) Indicator Method
8	Hardness(CaCO ₃)	48	200	600	mg/l	IS 3025 (Part 21- 2009)(RA 2023) EDTA Method
9	Calcium(Ca)	10	75	200	mg/l	IS 3025 (Part 40-2024) EDTA Titrimetric Method
10	Magnesium(Mg)	6	30	100	mg/l	APHA (24th Ed.2023) Method: 3500-Mg+2 B By Calculation Method
11	Chloride(Cl)	10	250	1000	mg/l	IS 3025 (Part 32-1988) Argentometric Method

This Report is issued under the following terms & Condition :

1. The results apply to the sample as received only.
2. The sample will be destroyed after retention time unless otherwise specified specially.
3. This report is not to be reproduce wholly or in part and can't be used be as evidence in court of law.
4. Abbreviation used (TDS = Total Dissolved Solids, mg/l = milligram per liter, BDL = Below detection limit, APHA = American Public Health Association, IS = Indian Standard, NT = Not Tested, NA = Not Applicable NTU = Nephelometric Turbidity Unit, RA = Reaffirmed, ND=Not Detected)
5. * Value not available or test not performed for this parameter.
6. Temperature condition limit: 25±5°C and Humidity condition limit:50 ±20%

M. Jitendra

Principal
Garden Valley International School
Kotla Bajwara, Sirhind

Reviewed and Approved By

Bhushan

Sh. Brij Bhushan
Quality Manager
Authorized Signatory
For, District Water Testing Laboratory
Fatehgarh Sahib

----- End of the Test Report -----

For Shaheed Bhagat Singh Educational
Trust & Management Society

Authorized Signatory

Page No. 1/1

DISTRICT WATER TESTING LABORATORY, FATEHGARH SAHIB

Water Supply & Sanitation Division, Opposite DC Residence, Fatehgarh Sahib

dwtlfgs@gmail.com

To,

Principal
Garden Valley International School Kotla Bajwara, Sirhind


No.: DWTLFGS/2425/00449 Dated : 10/03/2025

Subject : Testing Reports of Water Samples.

Reference: Your Letter/SRF No. Dated: 24/02/2025

As per above cited subject and reference, Please find enclosed here with the report of 1 Water sample/s received on dated 24/02/2025. It is request to fill the attached feedback form and send it back to District Water Testing Laboratory, Fatehgarh Sahib


D/A : Test Report



Authorized Signatory
For, District Water Testing Laboratory
Fatehgarh Sahib


Principal
Garden Valley International School
Kotla Bajwara, Sirhind

For Shaheed Bhagat Singh Educational
Trust & Management Society


Authorised Signatory